



Office of the District Fire Officer,
Karnataka State Fire and Emergency services,
Davanagere Fire station premises,
Davanagere Dist-577003.



C.No:20/CC/SCI/09/DFO/DVG/2024

Date:10/02/2024

To

The Principal
Genius Techno school
Near davanagere university
Hiretogaleri village ,
Mayakonda hobli
Davanagere Tq & District

Sir,

Sub: Issue of Compliance Certificate "Genius Techno School" Situated Sy No 84/6
Near Davanagere University, Hiretogaleri Village, Mayakonda Hobli,
Davanagere Tq, Davanagere District

Ref: 1) The district Fire Officer, davanagere Office Fire Safety Recommendation
C.No:20/R-FSR/SCI/09/DFO/DVG/2024 Date:07/02/2024
2) Your letter dated: 10/02/2024

>>>><<<<

With reference to subject cited above, Fire Safety Recommendation letter was issued vide reference (1) "Genius Techno School" Situated Sy No 84/6 Near Davanagere University, Hiretogaleri Village, Mayakonda Hobli, Davanagere Tq, Davanagere District with a condition to fulfill the recommendations and compliance the same.

With reference cited (2) above, The principal , "Genius Techno School" Situated Sy No 84/6 Near Davanagere University, Hiretogaleri Village, Mayakonda Hobli, Davanagere Tq, Davanagere District had requested for issue of the fire safety compliance report from our department. In this regard the building was inspected by me on 10/02/2024 to issue compliance Certificate.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance report" to "Genius Techno School" Situated Sy No 84/6 Near Davanagere University, Hiretogaleri Village, Mayakonda Hobli, Davanagere Tq, Davanagere District subject to proper maintenance of fire fighting installations in good working condition and impart 40% of employees should be trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore or the Regional fire officer, davanager range, davanagere fire station premises, davanagere within 90 days from the date of issue of this report.

This fire safety compliance certificate is valid till dated 09/02/2025 and it is renewable



Yours faithfully


District Fire Officer
Karnataka Fire & Emergency Service
Davanagere District



Office of the District Fire Officer,
Karnataka State Fire and Emergency services,
Davanagere Fire station premises,
Davanagere Dist-577003.



C.No:20/R-FSR/SCI/09/DFO/DVG/2024

Date:07/02/2024

To

The Principal
Genius Techno school
Near davanagere university
Hiretogaleri village ,
Mayakonda hobli
Davanagere Tq
Davanagere District

Sir,

Sub: Issue of 'Fire Safety Recommendation' to "Genius Techno School" Situated Sy No 84/6 Near Davanagere University, Hiretogaleri Village, Mayakonda Hobli, Davanagere Tq, Davanagere District

Ref: 1.Applicant Application Date: 28/12/2023.
2. GBC(2)044/2020-21 Date:21-06-2022

With reference to the subject above, the premises to "Genius Techno School" Situated Sy No 84/6 Near, Davanagere University, Hiretogaleri Village, Mayakonda Hobli, Davanagere Tq, Davanagere District was inspected me on 25/01/2024 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

Sl No.	Details	Observation
01.	Name and Address of the Applicant.	The Principal Genius Techno school Near davanagere university Hiretogaleri village , Mayakonda hobli Davanagere Tq Davanagere District
02.	Name and Address of the premises.	The Principal Genius Techno school Sy np 84/6



			Near davanagere university Hiretogaleri village , Mayakonda hobli Davanagere Tq Davanagere District
03.	Name & address of the building owner	:	The Principal Genius Techno school Near davanagere university Hiretogaleri village , Mayakonda hobli Davanagere Tq Davanagere District
04.	Number of buildings	:	01 Building , Ground +03 upper floors only
05.	Occupancy details of ground Floor	:	
	Ground floor	:	Office room, 07 class rooms
	First floor	:	08 class rooms, staff room
	Second floor	:	Office room, 07 class rooms
	Third floor	:	08 class room
06.	Height of the building	:	14.40 mtrs
07.	Site Area.	:	8093.65 Sqmtrs
08.	Built up area	:	
	Ground floor	:	643.02 Sq mtrs
	First floor	:	643.02 Sq mtrs
	Second floor	:	643.02 Sq mtrs
	Third floor	:	643.02 Sq mtrs
	Total built up area	:	2572.00 Sqmtrs
09.	<u>Surrounding properties:-</u>		
	East (front)	:	06 mtrs approach road which is connected to 12.00 mtrs davanagere – channagiri main road
	West (rear)	:	Agricultural land
	North (side)	:	Agricultural land
	South (side)	:	06 mtrs service road
10.	<u>Open space all around the building:-</u>		
	East (front)	:	7.00 Mtrs.
	West (rear)	:	06.00 Mtrs.
	North (side)	:	12.00 mtrs
	South (side)	:	01.00 Mtrs.
	Allowed setbacks (open space) should be maintained free from further obstruction / construction		



B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)																		
01.	Accessibility to the Premises	The premises is accessible from 06.00 mtrs wide Road, located on eastern Side which is connected to 12.00 mtrs davanagere – channagiri main road The Road is hardened to carry the weight of 45,000 kgs.	Adequate																		
02.	Number of entrances	02	Adequate																		
03.	Number of staircase	<table border="1"> <tr> <td>No. of staircases</td> <td>:</td> <td>01</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>1.60 mtrs</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>0.30mtrs</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>0.20 mtrs</td> </tr> <tr> <td>No. of risers per flight</td> <td>:</td> <td>12 nos</td> </tr> <tr> <td>Height of handrails</td> <td>:</td> <td>01.00 mtrs</td> </tr> </table>	No. of staircases	:	01	Width of staircases	:	1.60 mtrs	Width of treads	:	0.30mtrs	Height of risers	:	0.20 mtrs	No. of risers per flight	:	12 nos	Height of handrails	:	01.00 mtrs	Adequate
No. of staircases	:	01																			
Width of staircases	:	1.60 mtrs																			
Width of treads	:	0.30mtrs																			
Height of risers	:	0.20 mtrs																			
No. of risers per flight	:	12 nos																			
Height of handrails	:	01.00 mtrs																			
04.	Portable extinguishers	Provided 06 nos of ABC type extinguisher of 6 kg capacity and 02 nos of 2 kgs capacity Co2 type extinguisher in the building ,	complied																		
05.	Hose reel hose system	Provided 01 hose reel hose of 19mm size and of adequate length to reach the farthest point of each floor, with a shut off branch.	complied																		
06.	Automatic sprinkler system	Not required	Not required																		
07.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	provided 450 LPM capacity 01 booster pump	complied																		
08.	Diesel generator	Not Provided	Not complied Diesel generator of 25 KVA capacity to supply alternative power supply																		
09.	Terrace tank	provided 6,000 ltrs overhead tank to which the hose reel hose system is connected	complied																		
10.	Escape routes	Provided Directions in which the students and faculty should have to move in the event of any emergency have to be indicated in the corridor/passage on each floor as a guide during evacuation	complied																		
11.	Fire order (Fire safety plans)	Provided Notice boards indicating the details of action to be taken in case of	complied																		



		any emergency with telephone numbers of davanagere Fire station i.e. 08192-258101 101,112, and nearby ambulance service and police station	
12	No smoking board	displayed	complied
13	Fire Siren	Installed	complied
14.	Nominate one Fire Nodal Officer	--	Not complied A fire nodal officer shall be nominated either from teaching or non teaching staff.
15	Fire fighting training	Not imparted	At-least 40% of Teaching and non Teaching staff should be got trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore or Regional Training centre
16.	Fire precautionary measures :- <ol style="list-style-type: none"> Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. Accumulation of combustible waste in and around the premises should be avoided. The exit ways shall be always kept clear without any obstruction. Liquefied petroleum gas should not be stored in the building. The doors shall not be kept locked / latched during working hours and shall be free from obstruction. During the class hours the class room doors shall not be locked from inside to outside. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department. 		

Under above the circumstances the Karnataka Fire & Emergency Service Department is Issuing '**Fire Safety Recommendation**' to "Genius Techno School" Situated Sy No 84/6 Near, Davanagere University, Hiretogaleri Village, Mayakonda Hobli, Davanagere Tq, Davanagere District Subject to condition and compliance of the above recommendations in coloumn-4 of series-B within 3 months and compliance to the undersigned.

This '**Fire Safety Recommendation**' is valid for only one year from the date of issue and it is renewable.

❖ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of fire and life safety will have to be complied with mandatory



Yours faithfully

[Signature]
District Fire Officer
 Karnataka Fire & Emergency Service
 Davanagere District